

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7770-1243:104

Page 1 of 1

**CATEGORY:** Valves/Switches

**LISTEE:** Nibco Inc., 1516 Middlebury St., Elkhart IN 46515-1167  
Contact: \*Charles Stutsman (574) 295-3254 Fax (574) 523-3611

**DESIGN:** Model LD-3510-4, -8, WD-3510-4, -8 butterfly valves in the 2, 2-1/2, 3, 4, 5, 6, 8, 10 or 12 inches. All units have a rated working pressure of 250 psi. Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions and applicable codes and ordinances.

**MARKING:** Listee's name, model number and FM label.

**APPROVAL:** Listed as butterfly valves for use with fire sprinkler systems.

\*Rev. 06-06-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 16, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager